

VSFE/CE/91/20-21  
To

12-01-2021

The Chief Sevak  
Chinmaya Educational, Cultural & Charitable Trust  
Vazhuthacaud, Trivandrum. (Naruvammood school)

**CERTIFICATE**

We Hereby certify that the extinguisher(ABC 4kg=5 nos, CO2 2 kg=2 nos) received by us from your station for refilling purpose was duly refilled, tested and handed over to the authority concerned on 12-01-2021.

**Technical Specifications**

1. Extinguisher Type – ABC, CO2
2. Body Type - Sheet metal
3. Model No - N/A
4. Empty Weight - N/A
5. Charged Weight - N/A
6. Capacity - 2kg, 4 kg
7. Permissible Tolerance- N/A

Next Refilling Date: **11/01/2022**

For **VS Fireprotection & Fireengineers**

Authorised Signatory



VSF/CER/91/20-21  
To

12-01-2021

The Chief Sevak  
Chinmaya Educational, Cultural & Charitable Trust  
Vazhuthacaud, Trivandrum. (Naruvammood school)

**CERTIFICATE**

**Report of Hydrostatic Stretch Test**

We hereby certify that the extinguishers ABC&CO2 refilled your station for refilled,  
tested and handed over to the authority concerned on 12-01-2021.

EXTINGUISHERS NO	CAPACITY OF CYLINDER	TEST PRESSURE Kgs/Cm <sup>3</sup>	MEDIA OF TEST	PRESSURE HOLDING TIME	REMARKS
5NO	ABC 4 KG	30 Kgs\cm <sup>2</sup>	WATER	2 MINUTES	OK
2NO	CO2 2 KG	30 Kgs\cm <sup>2</sup>	WATER	2 MINUTES	OK

TOTAL NO. OF CYLINDER TESTED 7 NOS. ONLY

TESTED AND FOUND OK

NEXT H S T DUE ON **11-01-2022**

NEXT REFILL DUE ON: **11-01-2022**

For **VS Fireprotection&Fireengineers**

Authorised Signatory

