



Analytical Laboratory (Level II⁺)
Ground Water Department
Jalavijnana Bhavan, Ambalamukku,
Thiruvananthapuram, Kerala -695003.

Email: gwaltvm@gmail.com

(BIS: IS: 10500: 2012, REV 2018) Telephone: 0471 2437653

TEST REPORT

Report No: AL/T/712/25

Customer Name & Address	:	The Principal, Chinmaya vidyalaya, Vellappalli, Naruvamoodu P.O
Information Provided by the Customer	:	Pipe water
Date of receipt of sample	:	12/05/2025
Lab ID.	:	712/25
Date of start of Analysis	:	12/05/2025
Date of Completion of Analysis	:	30/05/2025
Date of issue of report	:	30/05/2025

TEST RESULTS

Sl. No	Parameters	Unit	Test Method	Acceptable Limit as per IS 10500: 2018, mg/l, Max	Results
1	Turbidity	NTU	IS 3025(part10): 2023	1	0.38
2	pH		IS 3025(part11): 2022	6.5- 8.5	7.6
3	Specific Conductance	µS/cm	IS 3025(part14): 2019		148
4	Total Dissolved Solids	mg/l	IS 3025(part16): 2023	500	89
5	Total Hardness as CaCO ₃	mg/l	IS 3025(part21): 2019	200	50
6	Calcium as Ca	mg/l	IS 3025(part40): 2019	75	18
7	Magnesium as Mg	mg/l	IS 3025(part46): 2019	30	1.2
8	Sodium	mg/l	APHA, 3500: Na B	-	7.7
9	Potassium	mg/l	APHA,3500: K B	-	3.5
10	Total Alkalinity as CaCO ₃	mg/l	IS 3025(part23): 2023	200	25
11	Carbonate	mg/l	APHA, 2320 : B	-	0
12	Bicarbonate	mg/l	APHA, 2320 : B	-	30.7
13	Chloride as Cl	mg/l	IS 3025(part32): 2019	250	18
14	Sulphate (as SO ₄)	mg/l	IS 3025(part24):2022	200	21
15	Nitrate (as NO ₃)	mg/l	IS 3025(part34):2023	45	3.94
16	Iron (as Fe)	mg/l	APHA, 3500 - Fe B	1.0	0.09
17	Total Coliform	CFU/ 100ml	APHA, 9222	NIL	Absent
18	E-Coli	CFU/ 100ml	APHA,9222	NIL	Absent



Authorized Signatory

Santhosh Kumar
30/5/25

End report

EXECUTIVE CHEMIST